

## **CMS ISSUES REQUIREMENT TO REDUCE LEGIONELLA RISK IN HEALTH CARE FACILITY WATER SYSTEMS - NEW POLICIES AND PROCEDURES REQUIRED**

On June 2, 2017, the Survey and Certification Group at the Centers for Medicare & Medicaid Services ("CMS") issued a memorandum, "Requirement to Reduce Legionella Risk in Healthcare Facility Water Systems to Prevent Cases and Outbreaks of Legionnaires' Disease (LD)" ("S&C Memo"), requiring that facilities develop and follow policies and procedures that inhibit microbial growth in building water systems to reduce the risk of growth and spread of Legionella and other pathogens in water. On June 9, 2017, the S&C Memo was revised to clarify provider types to apply to long-term care facilities, hospitals and critical access hospitals.

### **BACKGROUND**

The bacterium Legionella ("LD") can cause a serious type of pneumonia in persons at risk. Those at risk include persons who are at least 50 years old, smokers or those with underlying medical conditions such as chronic lung disease. In a recent review of LD outbreaks in the United States occurring in 2000-2014, 19 percent of outbreaks were associated with long-term care facilities and 15 percent with hospitals. Outbreaks generally are linked to environmental reservoirs in large or complex water systems, including those found in health care facilities such as hospitals and long-term care facilities. LD can grow in parts of building water systems that are continually wet, and certain devices can spread contaminated water droplets. Transmission from these water systems to humans requires aerosol generation, as can occur from shower heads, cooling towers, hot tubs and decorative fountains.

Part 483 to Title 42 of the Code of Federal Regulations require that skilled nursing facilities and nursing facilities must establish and maintain an infection prevention and control program designed to provide a safe, sanitary and comfortable environment and help prevent the development and transmission of communicable diseases and infections. Similar requirements exist for hospitals and critical access hospitals.

### **REQUIREMENTS FOR HEALTH CARE FACILITIES**

CMS requires Medicare-certified health care facilities to have water management policies and procedures to reduce the risk of growth and spread of LD and other pathogens in building water systems.

An industry standard calling for the development and implementation of water management programs was published in 2015 by the American Society of Heating, Refrigerating and Air-Conditioning Engineers ("ASHRAE"). In 2016, the Centers for Disease Control and Prevention ("CDC") developed a **toolkit** to facilitate implementation of this ASHRAE standard that includes environmental, clinical and epidemiologic considerations for health care facilities.

Surveyors will review policies, procedures and reports documenting water management implementation results to verify that facilities:

- Conduct a facility risk assessment to identify where LD and other opportunistic waterborne pathogens could grow and spread in the facility water system;
- Implement a water management program that considers the ASHRAE industry standard and the CDC toolkit and includes control measures such as physical controls, temperature management, disinfectant level control, visual inspections and environmental testing for pathogens; and
- Specify testing protocols and acceptable ranges for control measures and document the results of testing and corrective actions taken when control limits are not maintained.

### **SURVEY AND ENFORCEMENT**

The requirements in the S&C Memo are effective immediately. Facilities unable to demonstrate measures to minimize the risk of LD are at risk of citation for non-compliance with the CMS Requirements of Participation.

### **PRACTICAL TAKEAWAYS**

Facilities must immediately establish policies, procedures and reports documenting water management implementation results to

demonstrate that facilities:

- Conduct a facility risk assessment to identify where LD and other opportunistic waterborne pathogens could grow and spread in the facility water system;
- Implement a water management program that considers the ASHRAE industry standard and the CDC toolkit; and
- Specify testing protocols and acceptable ranges for control measures and document the results of testing and corrective actions taken when control limits are not maintained.

A link to the S&C Memo can be found [here](#).

If you have questions or would like additional information about this topic, please contact:

- **Todd Selby** at (317) 977-1440 or [tselby@hallrender.com](mailto:tselby@hallrender.com);
- **Brian Jent** at (317) 977-1402 or [bjent@hallrender.com](mailto:bjent@hallrender.com);
- **Sean Fahey** at (317) 977-1472 or [sfahey@hallrender.com](mailto:sfahey@hallrender.com); or
- Your regular Hall Render attorney.